

FORM 4 | TELL US ABOUT YOUR SEWAGE DISPOSAL SYSTEM

An existing sewage disposal system must comply with the setbacks outlined below:

Disposal Systems	Property Line	Water Source	Building	Septic Tank	Basement	Water Course
Holding Tank	1 m (3.25 ft)	10 m (33 ft)	1 m (3.25 ft)			10 m (33 ft)
Treatment Mound	3 m (10 ft)	15 m (50 ft)	10 m (33 ft)	3m (10 ft)	10 m (33 ft)	15 m (50 ft)
Treatment Field	1.5 m (5 ft)	15 m (50 ft)	5 m (17 ft)	5 m (17 ft)	10 m (33 ft)	15 m (50 ft)
Open Discharge	90 m (300 ft)	50 m (165 ft)	45 m (150 ft)			45 m (150 ft)
Lagoon	30 m (100 ft)	100 m (330 ft)	45 m (150 ft)			90 m (300 ft)
Packed Sewage Treatment Plant	6 m (20 ft)	10 m (33 ft)	1 m (3.25 ft)			10 m (33 ft)

Source: Alberta Private Sewage System Standards of Practice (2015)

An existing private sewage system may have to be inspected as a condition of subdivision approval to ensure compliance with the requirements listed above. Should the existing sewage system not be compliant with the current code of practice, you will be required to upgrade to a compliant system at your own expense.

We strongly recommend that you research installation costs with accredited private sewage contractors.

1. Legal Land Description

Lot/Block/Plan _____

Quarter Section _____

2. What type of sewage disposal system do you currently have?

Open discharge (gray water)

Treatment Field System

Treatment Mound

Other (Please Specify) _____

3. When was the sewage disposal system installed?

4. What is the holding capacity of the sewage disposal system?

5. Who installed the sewage disposal system (if known)?

6. Distance from the sewage disposal system to the house:

Signature

Date

FURTHER INFORMATION MAY BE PROVIDED AS AN ATTACHMENT